



Certification Record

CUSTOMER	CLASS	FILE
Warmly Yours.com, Inc. 2 Corporate Dr, Suite 100, Long Grove IL 60047 USA	2872-01 HEATERS-Cable and Cable Sets	247310
Refer to Class Description for program details		

TO THE REQUIREMENTS OF CSA STD. 130-03:

Series Heating Cable Sets, two-conductor constructions of:

a) cat. nos. SHC (non-mat construction), and SHM (mat construction), indoor embedded floor warming (usages W, X), 20W/m maximum, 6000W maximum, rated at 500V maximum, maximum temperature rating 70°C.

b) cat. nos. WHCS (non-mat construction) and WHMS (mat construction), outdoor embedded and roof and gutter de-icing (usages WS, X), 40W/m maximum for embedded tracing and 18 W/m maximum for roof & gutter de-icing, 6000W maximum, rated at 500V maximum, maximum temperature rating 70°C.

c) cat. nos. WHCA (non-mat construction) and WHMA (mat construction), outdoor embedded snow melting (usages WS, X), 40W/m maximum, 6000W maximum, rated at 500V maximum, maximum temperature rating 70°C.

Notes:

1. Installation in accordance with the Canadian Electrical Code Part I (CEC Part I).
2. The Cat No may include suffixes to denote construction options.
3. The manufacturer's minimum recommended installation temperature for these heating cable sets is -15°C.

/jj