



Certification Record

CUSTOMER	CLASS	FILE
Warmly Yours.com, Inc. 2 Corporate Dr, Suite 100, Long Grove IL 60047 USA	2872-81 HEATERS-Cable and Cable Sets - Certified to US Standards	247310
Refer to Class Description for program details		

TO THE REQUIREMENTS OF UL 515 AND IEEE 515.1-2005:

Series Heating Cable Sets, two-conductor constructions of:

a) cat. nos. SHC (non-mat construction), and SHM (mat construction), indoor embedded floor warming (space heating cables installation beneath floors of enclosed structures), 20W/m maximum, 6000W maximum, rated at 500V maximum, maximum temperature rating 70°C.

b) cat. nos. WHCS (non-mat construction) and WHMS (mat construction), outdoor embedded and roof and gutter de-icing (Installation Types B & C), 40W/m maximum for embedded tracing and 18 W/m maximum for roof & gutter de-icing, 6000W maximum, rated at 500V maximum, maximum temperature rating 70°C.

c) cat. nos. WHCA (non-mat construction) and WHMA (mat construction), outdoor embedded snow melting (Installation Type C), 40W/m maximum, 6000W maximum, rated at 500V maximum, maximum temperature rating 70°C.

Notes:

1. Installation in accordance with the National Electrical Code (NEC).
2. The Cat No may include suffixes to denote construction options.
3. The manufacturer's minimum recommended installation temperature for these heating cable sets is -15°C.

/jj